



EUROPEAN ECONOMIC CHAMBER OF TRADE, COMMERCE AND INDUSTRY

European Economic Interest Grouping

OFFICE OF THE SPEAKER OF THE BOARD OF DIRECTORS
EEIG EU Standards Certification Secretariat
email: eurocott@gmail.com

SECRETARIAT OFFICE
PO Box 40668
Larnaca, 6306, Cyprus
Tel. +357 97619908

BRUSSELS Head Quarters
Rue des Colonies 11
B-1000 Brussels

EEIG EU STANDARD FOR ECOLOGICAL CONSTRUCTION

(Private Houses, Offices, Company Buildings, Civil Construction Projects)

(EU-EcoCon-QS)

Revision April 2012

Aims of the Standard

- 1) To encourage all Ecological Construction to achieve agreed EU standards in:
 - a) how they are run
 - b) how they manage their businesses; and
 - c) the experiences of users
- 2) To encourage confidence in Ecological Construction Companies as organisations that use ecological methods and materials in the construction of private houses, offices, company buildings, civil construction projects and satisfaction for their clientele.
- 3) To reinforce a shared ethical and professional basis for the Ecological Construction Industry
- 4) To ensure that all national legal requirements with regard to establishing and carrying on food preparation and serving to the public have been considered and respected. These requirements concern particularly laws, decrees and edicts for health issues and no ecological site can be certified by the EU Standards for Ecological Construction unless conform to the national laws and rules concerning hygiene in their establishments.
- 5) To ensure the conformity of Ecological Construction with relevant:
 - a) ISO standards as mentioned in 4 above;
 - b) legal prescriptions and stipulations as to waste;
 - c) general European standards and relevant EU guidelines as far as existing, e.g. the EEC-directive on minimum requirements for the protection of human health, the EEC-directive on the quality of materials and methods used, EEC-directive on ecology etc.

Establishments that may apply for the EEIG EU Standard for Ecological Construction
Construction Companies involved in the ecological construction of Private Houses, Offices, Company Buildings, Civil Construction Projects.

Benefits of taking part in the EEIG EU Standards Certification Scheme

Performance - A quality standard that serves as an authoritative benchmark for assessing performance, rewarding achievement and driving improvement.

Administration: B-1000 Brussels, Rue des Colonies 11

URL: <http://www.european-economic-chamber-eeig.eu/> E-mail: sieeurope@sieeurope.eu

- Profile - It raises awareness and understanding of Hotels, so building confidence and credibility both within the establishment and among the public.
- People - It helps ECOLOGICAL CONSTRUCTION to improve their focus on meeting users' needs and interests and developing their workforce.
- Partnerships - It helps ECOLOGICAL CONSTRUCTION to examine their services and facilities and to encourage joint working within and between organisations.
- Planning - It helps with forward planning by formalising procedures and policies.
- Patronage - It demonstrates that the ECOLOGICAL CONSTRUCTION has met an EU standard, which strengthens applications for public and private funding and gives investors confidence in the organisation.

Eligibility

To be certified, ECOLOGICAL CONSTRUCTION must:

- meet the EEIG's 2012 definition of ecological construction must promote ecological construction methods and materials.
- be registered at National level
- have a formal constitution
- provide two years of relevant accounts
- meet all relevant legal, ethical, safety, equality, environmental and planning requirements
- be committed to forward planning to improve the service for users
- Meet the following specific additional requirements:
 - **Protection of human health** - Additional to the aforementioned legal stipulations concerning the hygiene and cleanliness, also the national requirements with regard to the quality of air (smoking/emissions) and noise levels have to be considered and respected.
 - **Precautions for disabled and handicapped people** - All buildings, installations and equipments have to take care of disabled and handicap persons according to currently valid national and international stipulations and standards.
 - **Fire protection** - The currently valid national technical stipulations of the fire brigades have to be considered and respected as a means of preventive protection against fire.
 - **Energy economy** - Energy saving means and measures have to be taken into account in all areas of the ecological construction organisation. They have to meet the most recent state-of-the-art techniques and latest developments in research (e.g. solar cells, heat pumps, insulation, thermal energy).
 - **Environment protection** - Ecology and measures of sustainability and environment protection have to be taken into account. The whole enterprise has to work according to healthy, non-polluting, nature friendly and environmentally beneficial methods.

Categorizing the Standard

- Ecological Construction Companies
- Ecological Building or Project

Note: these establishments can be stand alone or within Ecological Construction and ancillary premises.

Assessment of the Enterprise and its Services

To obtain a total assessment of the enterprise and establishment including equipments etc it is necessary to judge the situation of the establishment, the buildings, the equipment, and facilities according to the "European Ecological Construction Standard".

PROCEDURE OF CLASSIFICATION

for Ecological Construction of Private Houses, Offices, Company Buildings, Civil Construction Projects

1. **The Central Office for the Classification of Quality Standards** - All applications for a classification shall be directed to our Headquarters in Brussels. The Central Office allocates the appropriate validator of the European Economic Chamber of Trade, Commerce and Industry to be engaged with the classification procedure of the applicant organisation. The validator will then proceed with the review, assessment and evaluation of the application and checklist. The final classification will be effected by the Central Office according to the evaluation and recommendation of the National Commission and validator.
2. **Classification – Application and Procedure** - The owner or manager of the wellness enterprise and establishment applies for a classification by the European Economic Chamber of Trade, Commerce and Industry in writing and asks the Central Office or National Commission for a checklist and a visit of an expert of this commission. After reviewing and assessment of the wellness and fitness establishment by a personal visit of the validator, the checklist will be evaluated. The commission carries out the evaluation within sixty days from the receipt of the application including the assessment of management procedures, the suitability of the premises, facilities, resources and treatments. The National Commission informs the owner or manager of the result of the classification procedure in writing. The relevant Certificate will be issued by the Central Office for Classification in Brussels.
3. **Dealing with Objections** - The contact person of the wellness enterprise and establishment can file an objection against the classification or against not being classified within sixty days. The contact person may object within four weeks after receipt of the decision of the Central Office for Classification or non-receipt of one after the expiration of 60 days from the lodgement of the application. This objection has to be directed to the National Commission and has to be done in writing (by registered mail) explaining the reasons for the objection. The Central Office will consider the reasons of objection and engage the National Commission to re-check the present classification. The final decision will be made within four weeks. Court of jurisdiction is Brussels.

THE STANDARD - Requirements for EEIG EU Ecological Construction Standards Certification

A) **COMPULSORY Statutory Requirements**

- 1) Registration as a business
- 2) Registered Hotel or National Business Registration
- 3) Business Plan
- 4) Organization Chart
- 5) Ethical Brochure or advertising material
- 6) Local Chamber of Commerce Membership
- 7) VAT Registration
- 8) Health & Safety Registration
- 9) Social Security Registration
- 10) Accounts Available
- 11) At least 1 persons in the organisation must have been certified for First Aid by a National Authority

B) **GENERAL Requirements**

- 1) Brochure, website

C) **STAFFING (Minimum)**

- 1) As per Classification Requirements
- D) **Environmental factors:**
 - 1) Water Efficiency
 - 2) Waste Reduction & Recycling
 - 3) Sustainable Furnishings and Bldg Materials
 - 4) Sustainable Food
 - 5) Energy
 - 6) Disposables
 - 7) Chemical & Pollution Reduction
- E) **CUSTOMER SERVICE**
 - 1) The whole impression of the premises is clean
 - 2) Reception staff are friendly
 - 3) The general ambiance is good
 - 4) Staff available with competency in English
 - 5) The requirements and wishes, respectively, of clients are completely met
 - 6) The service is friendly
 - 7) The service is quick
 - 8) The service is efficient
 - 9) Clients are given a feedback form which is reviewed by management

All the above have been summarised in the EEIG EU Standards for Ecological Construction as follows:

And in particular:

EEIG EU ECOLOGICAL CONSTRUCTION STANDARD QUALITY SEAL

A - GENERAL

A.1. Quality Seal - The quality seal EU-ECOCON-QS qualifies products and services which allow a more efficient input of energy and a broader use of sustainable energies and at the same time improve the quality of living, protect the competitiveness, and reduce the damage to the environment. The main aim of the quality seal is to strengthen the confidence in these products and services.

The products and services have to comply with general requirements to be in agreement with the specifications of the European Quality Standard for Ecological Housing. For the given reason,

- (a) the total energy consumption has to be at least 25% less and the fossil energy consumption at least 50% less than the average of the latest technological development,
- (b) the whole construction, installations, performance and implementation have to ensure at least the same comfort as actually customary,
- (c) the whole construction, installations, performance and implementation have to be offered at competitive prices, i.e. the price must not exceed the price of comparable, conventional products by more than 10%,
- (d) the waste management of the consumed goods has to be at least as problem-free as of conventional goods.

A.2. Property - Owner of the European Quality Standard for Ecological Housing is the European Economic Chamber of Trade, Commerce and Industry (EEIG). At the request of interested parties, the owner can allow the right of use of the European Quality Standard for Ecological Housing and the relevant quality seal for an unlimited time. The right of use may gain property developers, builder owners, master builders, architects, producers of building and construction materials, and the producers of absorbent and insulating materials.

A.3. Conformity - The quality seal can only be used if the offered products and services are in conformity with general legal requirements (e.g. national construction standards, local fire police instructions, EN 832/September 1998, EN ISO 6946/January 1997, EN ISO 7345/May 1996, EN ISO 10211-1/March 1996, EN ISO 13370/October 1998, EN ISO 13789/July 1997, EN ISO 10077-1/December 2003, etc.) as a precondition and with the specific stipulations of the European Quality Standard for Ecological Construction. The user of the quality seal has to be registered at the European Economic Chamber of Trade, Commerce and Industry (EEIG).

A.4. Controls - The obedience to the European Quality Standard for Ecological Construction can be monitored and controlled by spot checks by the experts of the European Economic Chamber of Trade, Commerce and Industry (EEIG) or by independent institutions, e.g. consulting engineers, sworn appraisers, national institutes for heating and ventilation engineering, institutes for air-conditioning engineering, institutes for building material technology, institutes for construction technique, institutes for environmental technologies, and institutes for ecological house building.

Disobedience can be sanctioned by withdrawal of the right of use, debiting of examination expenses and administrative fees, payment of penalty for breach of contract, and claim of compensation, in case of damage by misuse.

A.5. Fees - The fees for using the brand and quality seal of the European Quality Standard for Ecological Construction depend on the extent of the project.

A.6. Liability - The European Economic Chamber of Trade, Commerce and Industry (EEIG) as owner of the European Quality Standard for Ecological Housing and the quality seal offers only information. From using this information cannot be deduced any compensation.

B - Area of application

The area of application includes housing (detached family homes, multiple dwelling houses for several families), blocks of flats (apartment houses), hotels, administration, offices, schools, sales rooms, restaurants, meeting places, hospitals, health resorts and wellness centres, industrial buildings, store rooms, sports halls, and indoor swimming pools.

C - Assessment criteria

For the assessment and evaluation of the practical results of using the European Quality Standard for Ecological Housing serves a system of 1,000 ecological points, according to the following catalogue:

1	Planning and performance	maximum	140 points
1.1	Quality of infrastructure (near to school, supermarket, pharmacy, sports hall, cultural centre, etc.)		15
1.2	Storeroom for bicycles		10
1.3	Hindrance-free building – outside (to avoid accidents) ¹⁾		20
1.4	Hindrance-free building – inside (to avoid accidents) ¹⁾		20
1.5	Building surface, heat bridges sparse ²⁾		25
1.6	Building surface, heat bridges free ²⁾		35
1.7	Building surface airtight (standard) ³⁾		20
1.8	Building surface airtight (with special ventilation) ³⁾		40
2	Energy supply for heating purposes	maximum	545 points
2.1	Calculation of the heating energy demand		150
2.2	Heating with coal, coke, or electric resistance heating		0
2.3	Heating with natural gas or oil		0
2.4	Heat pump monovalent (without thermal recovery) ⁴⁾		100

2.5	Heat pump compact aggregate ⁴⁾	250
2.6	District heating and long-distance supply ⁴⁾	300
2.7	Heating with biogene fuels ⁴⁾	200
2.8	Electric water heater ⁵⁾	25
2.9	Electric hot-water tank ⁵⁾	55
2.10	Solar hot-water supply ⁵⁾	95
3	Electric energy supply for other purposes	maximum 90 points
3.1	Mechanical ventilation (with comfort and energy-efficient use)	25
3.2	Lighting (energy-saving use)	10
3.3	Rinsing and washing with warm water	10
3.4	Photovoltaic installations	45
4	Water supply	maximum 30 points
4.1	Wash-basin with water-saving water tap	10
4.2	Shower with water-saving hothead	10
4.3	Bath tube with water-saving hothead	10
5	Building material and construction	maximum 85 points
5.1	Insulating materials (free of HFCHC)	5
5.2	Windows, doors, shutters and blinds (free of PVC)	10
5.3	Pipes, films, layers, coating, covering, wallpapers (free of PVC)	20
5.4	Bitumen and other paintings, adhesives (free of solvents)	5
5.5	Building material, ecologically optimized	15
5.6	Ecological assessment of the whole building ⁸⁾	30
6	Air quality and amenities	maximum 110 points
6.1	The building is suitable for summer (cool rooms etc.)	15
6.2	Fresh air ventilation (sound absorbing) ⁶⁾	20
6.3	Comfort fresh air ventilation (soundproof, filter, free of CO ₂) ⁶⁾	30
6.4	Floor covering materials, filler, adhesives (free of VOC) ⁷⁾	5
6.5	Floor covering materials, filler, adhesives (free of VOC and CMT) ⁷⁾	15
6.6	Wooden parts of the building (free of emissions)	10
6.7	Paintings of walls and ceilings (free of emission)	10
6.8	Measuring of volatile hydrocarbons and formaldehyde	30
Total evaluation		maximum 1,000 points

A certification according to the European Standard of Ecological Housing with the right of using the quality seal of the European Economic Chamber of Trade, Commerce and Industry (EEIG) can take place when at least 750 points of 1,000 possible points are reached.

Explanatory remarks:

- 1) 2) 3) 4) 5) 6) 7) = alternatively used
 8) = additionally
 VOC = organic volatile compounds
 CMT = carcinogenic mutagenic and teratogenic compounds
 HFCHC = halogenous fluoride chloride hydrocarbons

D - EXPLANATIONS & TECHNICAL FACTORS IN THE ASSESSMENT PROCESS

Buildings according to the European Quality Standard for Ecological Housing are buildings with a very low demand of thermal energy. They have an energetically efficient and silent mechanic ventilation, an energetically efficient hot-water system and water-saving fittings. The use of gas and oil is permissible if the heating technologies applied are efficient and other measures are used to reduce the emission of harmful substances (insulation, filters) and to recycle thermal energy etc.

Further criteria of ecological buildings are environmentally beneficial building materials and constructions, non-polluting installations, and a high living comfort because of a good fresh air quality inside (free of emissions from outside) and protection against humidity, bad smell, and mould.

Planning and performance

1.1 All places to cover the daily need (shopping, school, doctor etc.) should be within a radius of 500 m to be able to do it without car or only by bicycle (for distances up to 4 kms.. Without traffic, there is a higher living quality since less dust, noise and exhaust fumes are produced.

1.2 The minimum storeroom for bicycles is 0.05 m² per m² gross area of heated floor (BGF_h). The storeroom should be ground level and, if necessary, with a ramp. The thermal need can be calculated with 5 WE (thermal energy unit) per m².

1.3 To avoid accidents, especially of elderly persons, there should be no barriers and hindrances, e.g. sills, thresholds, embankments, near the entrance of the building and in the surroundings.

1.4 For the same reason, there should be no thresholds inside the building. Doors and passages should have a breadth of at least 0.80 m. Toilets, bathrooms (bath tubs, and showers should be on the same level as the floor. Inside these rooms should be a turning circle of at least 1.50 m.

1.5/1.6 The loss of thermal energy in parts of the construction with a low surface temperature should be avoided because that causes, besides higher cost for energy, condensates on the inner side and damage of the construction. The result can be high humidity and mould on these parts (walls etc.) which damages the health and reduces the living quality. Using the right materials and methods the need of thermal energy can be reduced by 12 kWh/m²_{BGF-a}.

1.7/1.8 The aim is to have an airtight building since leaks cause humidity and structural damages which is particularly essential for occupied attics because of smoke and smells from neighbouring apartments. There is also a higher level of noises in building that is not airtight. In old houses with normal leaks the air exchange rate amounts to $n < 0.6 \text{ h}^{-1}$. The air exchange rate of mechanically ventilated buildings is $n < 1.5 \text{ h}^{-1}$.

2.1 The main aim of ecological houses according to the European Quality Standard for Ecological buildings is to reduce the total need of thermal energy to save costs and to reduce ecological damages, mainly by emissions. Optimized ecological buildings can reduce the need of thermal energy by 35-40% or roughly $45 \text{ kWh}/(\text{m}^2_{\text{BGFh}\cdot\text{a}})$.

The specific demand of thermal energy related to area (HWB_{BGF}) is the amount of energy per heated m^2 of the building to hold an inside temperature of 20°C at a certain place (depending on the climate) during one year. The ratio for the compactness of a building is $1/lc = A/V$. The thermal energy demand depends not only on the compactness, air tightness, building materials and insulations used but also on the sea level, strength of wind, directions, percentage of doors and windows and other parts of lightweight construction.

2.2/2.3 It should be paid attention to keep the needed amount of primary energy and the emission of CO_2 as small as possible. Since the transmission ration ($\text{kWh}_{\text{prim}}/\text{kWh}_{\text{end}}$) of electricity (approx. 3) is rather unfavourable in comparison e.g. to gas (1.1), the share of electric energy should be kept below $2 \text{ kWh}/\text{m}^2$.

2.4/2.5 Heat pumps with a seasonal performance factor (SPF) of 4.0 are able to reduce the CO_2 emission in comparison to gas heating by nearly 20%. This seasonal performance factor describes the ratio of heating output to the electric power input. The heating systems work with water temperature less than 35°C . Usually only 80% of the total heat can be covered by this system.

2.6 The most efficient way to use the primary energy of district heating is to combine heating and hot-water preparation.

2.7 Using these means helps to become independent from non-regenerative fuels and to reduce the CO_2 emission by relying on sustainable fuels as e.g. wood pellets and bio-mass.

2.8/2.9 Since the transmission factor of electric energy is rather inefficient, general heating of water by electricity as a primary energy should be avoided. Hot-water tanks should have an insulation of at least 10 cm with a conductivity of the insulating material of $0.04 \text{ W}/(\text{m}\cdot\text{K})$. Example for an energy loss calculation:

Storage volume: 500 litres

Product specific thermal loss factor: 3.0

Middle storage temperature: 55°C

Middle room temperature: 20°C

Thermal energy loss of the tank: $3.0 * (55 - 20) = 105 \text{ W}$

Thermal energy loss of insulated hot-water tanks:		
Storage volume (litres)	Thermal loss (Watt) insulation	
	10 cm	15 cm
25	20	15
50	29	22
75	37	28
100	43	32
150	54	41
200	64	48
300	80	60
500	108	81
750	137	103
1000	162	122
1500	207	155
2000	247	185

2.10 Thermic solar systems can contribute to a considerable amount to the total demand of primary energy for the hot-water supply.

3.1 Using energy efficient direct current (DC) ventilation with thermal recycling, the needed electricity can be reduced by 260 kWh/a per year. The electric power need should be less than $0.3 \text{ W}/(\text{m}^3 \cdot \text{h})$.

3.2 As the consumption of electric energy of households is rising it is essential to find means to reduce it, e.g. by sensible using of movement signals, automatically operating switches, energy-saving lamps, neon tubes with electronic bulkhead units.

3.3 Cold and hot water-service pipe (taps) for dishwashers and washing-machines.

3.4 Photovoltaic installations can be integrated on roofs, facades, carports etc. Their dimension should be $1 - 5 W_{\text{peak}}$ per m^2_{BGFh} .

4.1/4.2/4.3 It makes sense to save water, not only by financial and energetic reasons but also to take care of the environment and the valuable drinking water and hot water. Therefore, the consumption of water should be reduced to:

wash-basin	maximum 6 litres per minute
water-saving hotheads	maximum 9 litres per minute
bath tubes	maximum 12 litres per minute

5. General principles for all building materials and construction are:

- avoiding materials which contain halogenous fluoride and chloride hydrocarbons and tropical woods
- avoiding of materials which show weaknesses during their life cycle, e.g. PVC
- avoiding of materials contain solvents and other substances which cause problems in the waste management
- pushing products which have good qualities during their life cycle, as e.g. ecologically tested materials
- ecologically optimized use of building materials and constructions.

6.1. The aim is to build houses which are not too hot in summer and which do not need to be refurbished with cooling aggregates at a later stage.

6.2/6.3 The fresh air ventilation should be steered by the content of humidity, CO_2 and dust particles. It should operate in a silent way. The internal leak stream should be less than 3% with 100 Pa. There should be a three degrees or a continuous regulation. The fresh air inflow in a standard house for one family is approx. $30\text{m}^3/\text{h}$. The inflowing air should have a temperature of at least 17°C to minimize draught phenomena. The air exchange rate amounts to more than 0.3 h^{-1} .

6.4/6.5 The limits of total organic volatile compounds are less than:

- 100 $\mu\text{g}/\text{m}^3$... for filling material
- 200 $\mu\text{g}/\text{m}^3$... for adhesives
- 500 $\mu\text{g}/\text{m}^3$... for floor covering materials

Final limits of emission of elastic floor coverings on the 28th day:

Aromates incl. Styrol	70 $\mu\text{g}/\text{m}^2 \text{ h}$
Halogenous volatile organic compounds	40 $\mu\text{g}/\text{m}^2 \text{ h}$
Total of volatile organic compounds	380 $\mu\text{g}/\text{m}^2 \text{ h}$

Smell and irritating substance:

Nonanal	70 $\mu\text{g}/\text{m}^2 \text{ h}$
Hexanal	20 $\mu\text{g}/\text{m}^2 \text{ h}$
Styrol	30 $\mu\text{g}/\text{m}^2 \text{ h}$

Final limits of emission of textile floor coverings on the 28th day:

TVOC	< 300
------	-------

6.6 Final limits of emission of wood, e.g. doors, panelling, laminates, finished parquet, on the 28th day:

Formaldehyde	0.05 ppm
Organic compounds (boiling point 50-25)	300 $\mu\text{g}/\text{m}^3$
Organic compounds (boiling point > 250°C)	100 $\mu\text{g}/\text{m}^3$
CMT substances	< 1 $\mu\text{g}/\text{m}^3$

6.7 Approx. ¾ of all areas of a building are walls and ceilings. Limits of emission of pain-tings of walls and ceilings (volatile organic compounds):

Synthetic resin dispersion	max. 0.1 (mass)%
Natural resin dispersion	max. 1.0 (mass)%
Other organic substances in silicate dispersion	max. 5.0 (mass)%

All organic compounds with a boiling point of max 250°C at normal pressure (101,3 kPa) should follow the stipulations of EC/2002/739 of the European Commission.

6.8 The air quality should be measured 28 days after finishing of the rooms. The total content of organic volatile compounds (TVOC) must be less than 500 $\mu\text{g}/\text{m}^3$. The limit of formaldehyde concentration has to be less than 0.05 ppm.

E - Additional technical data

Influence of climatic conditions: For every 100m difference of level there are supplements of:

+/- 3%	to HGT
+/- 8%	to HT
+/- 0.5 K	to θ_i

Inside temperature (θ_i):

Residential buildings, offices, schools	$\theta_i = 20 \text{ }^\circ\text{C}$
Hospitals, nursing homes	$\theta_i = 22 \text{ }^\circ\text{C}$
Industrial buildings	$\theta_i = 18 \text{ }^\circ\text{C}$

Heating grade days:

HGT = HT * ($\theta_i - \theta_e$) Kd/M (per month), resp. Kd/a (per year)

Ventilated net volume of the building:

$V_N = 0.75 * V_B = \dots \text{ m}^3$

Gross area of heated floor:

$BGF_B = \dots \text{ m}^2$

Gross area of heated attic:

$$BGF_{B,DG} = V_{B, DG} / h_{DG} = \dots m^2$$

Characteristic length of building:

$$l_c = V_B / A_B = \dots m$$

Area of glass and frames:

$$A_g = f_g * A_w = \dots m^2$$

$$A_f = (1 - f_g) * A_w = \dots m^2$$

$$f_g = 0.7$$

Length of window frames:

$$l_g = 3 * A_w = \dots m$$

Total heat energy demand:

$$Q_h = (Q_T + Q_V) - \eta * (Q_i + Q_s) = \dots \text{ kWh/M (per month), resp. kWh/a (per year)}$$

Transmission loss of thermal energy:

$$Q_T = 0.024 * L_T * HGT = \dots \text{ kWh/M (per month), resp. kWh/a (per year)}$$

Transmission factor of the building envelope:

$$L_T = L_e + L_u + L_g + L_\psi + L_\chi = \dots \text{ W/K}$$

Transmission factors for building parts:

$$L_e + L_u + L_g = \sum_i f_i * U_i * A_i = \dots \text{ W/K}$$

Additive factor for thermal bridges:

$$L_\psi + L_\chi = 0.2 * [0.75 - (L_e + L_u + L_g) / A_B] * (L_e + L_u + L_g) > 0. \dots \text{ W/K}$$

Heat transfer coefficient for building parts:

$$U_i = 1 / (R_{si} + \sum_m \frac{d_m}{\lambda_m} + R_{se}) = \dots \text{ W/(m}^2 \cdot \text{K)}$$

Heat transfer coefficient of windows:

$$U_w = (A_g * U_g + A_f * U_f + l_g * \psi_g) / (A_g + A_f) = \dots \text{ W/(m}^2 \cdot \text{K)}$$

Temporary heat protection:

It can be achieved by roller blinds and folding shutters.

Middle heat transfer coefficient of heat emitting building envelope:

$$U_m = L_T / A_B = \dots \text{ W/(m}^2 \cdot \text{K)}$$

Ventilation heat losses:

$$Q_V = 0.024 * L_V * HGT = \dots \text{ kWh/M (per month), resp. kWh/a (per year)}$$

Ventilation factor of the building envelope:

$L_V = \rho_a * c_a * n * V_N = \dots \text{ W/K}$ (In this equation the specific thermal capacity of the air is equivalent to $\rho_a * c_a = 0.33 \text{ Wh/(m}^3 \cdot \text{K)}$)

Air-exchange rate:

The air exchange depends on the purpose of the building. Normally, the air-exchange rate is $n = 0.4$... in 1/h – For reasons of hygiene, there can be higher air-exchange rates.

The air-exchange rate in heat recovering systems is

$n = q_{v,i}/V_N * (1 - \eta_v) + n_x =$... in 1/h as has to be higher than 0.4/h.

Heat supply factor:

The heat supply factor of a geothermal exchanger (EWT) is

$$\eta_{v,ges} = 1 - (1 - \eta_{v,eff}) * (1 - \eta_{v,EWT})$$

An additional air-exchange rate for false air (infiltrated air) has to be considered:

> 0.6 fold air exchange with air leakproofness test	$n_x = 0.04$
0.6 – 1.0 fold air exchange with air leakproofness test	$n_x = 0.07$
1.0 – 1.5 fold air exchange with air leakproofness test	$n_x = 0,12$
> 1.5 fold air exchange with air leakproofness test ...	$n_x = 0,20$
without any air leakproofness test	$n_x = 0,20$

If the manufacturer's data of heat exchangers are ...% (η_v) the real heat supply ($\eta_{v,eff}$) is....% taking into account a general reduction of 12% for the installation of ventilation systems:

stream-crossing heat exchanger	$\eta_v = 65\%$	$\eta_{v,eff} = 53\%$
counter-current and rotation heat exchanger	$\eta_v = 85\%$	$\eta_{v,eff} = 73\%$
counter-current canal heat exchanger	$\eta_v = 90\%$	$\eta_{v,eff} = 78\%$
heat pump with or without static heat exchanger	---	$\eta_{v,eff} = 78\%$

The real efficiency of geothermal heat exchanger is around:

$$\eta_{v,EWT} = 20\%$$

Air leakproofness test:

This test has to be done in at least 25% of all apartments of an apartment building, 50% of them have to be apartment in exposed situation (e.g. corner apartments), further all apartments with dry construction walls, and all apartments with skylight windows.

Solar heat gains via transparent construction parts:

$$Q_s = \sum_i I_i * (\sum A_g * f_s * g_w)_i = \dots \text{ kWh/M (per months), resp. kWh/a (per year)}$$

Orientation:

It is part of the clima and depends also on azimuth and inclination. Roof windows with an inclination of more than 15° to the horizontal are treated like vertical areas, windows with an inclination of less than 15° are treated like horizontal transparent areas.

Reduction factor for shading:

Shading is the reduction of solar radiation by topographic and structural obstacles (balconies, recessed balconies/loggias, protruding building edges), trees and bushes etc.

unshaded location	$f_s = 0.9$
shaded location	$f_s = 0.6$

Windows are regarded as shaded if more than 50% are shaded.

Total energy permeability factor:

It is denominated g . If the glass of the windows is dirty and their inclination is not vertical the effective energy permeability extent of glass is defined as:

$$g_w = 0.9 * g \text{ (i.e. it is reduced by 10\%)}$$

Winter gardens:

Heat gains by solar radiation are only calculated if there is a direct irradiation of the glass areas.

Transparent heat insulation:

Heat gains via transparent heat insulation can be included:

on the south, east, and west side + 20%
 on the north side + 10%
 to the heating energy demand.

Internal heat gains:

They are caused by electric gears, lighting, and the body temperature of persons. It is

$$Q_i = 0.024 * q_i * BGF_B * HT = \dots \text{ kWh/M (per month), resp. kWh/a (per year)}$$

The middle heat flow density (q_i) can be calculated as follows:

Residential buildings, offices, schools	$q_i = 3.0 \text{ W/m}^2$
Hospitals, nursing homes	$q_i = 4.0 \text{ W/m}^2$
Industrial buildings	$q_i = 5.0 \text{ W/m}^2$

Exploitation factor of heat gains:

It can be calculated according to the equation:

$$\eta = (1 - \gamma^a) / (1 - \gamma^{a+1}) \dots \text{ if } \gamma \neq 1$$

$$\eta = a / (a + 1) \dots \text{ if } \gamma = 1$$

or using the factor:

$$\eta = 1.00 \quad \text{for heavy constructions}$$

$$\eta = 0.98 \quad \text{for light-heavy constructions}$$

$$\eta = 0.90 \quad \text{for light constructions}$$

Ratio of heat gains to heat losses:

$$\gamma = (Q_s + Q_i) / (Q_T + Q_V)$$

The numeric parameter is

$$a = 1.0 + \tau/16 \text{ for calculating on a month basis}$$

$$a = 0.8 + \tau/28 \text{ for calculating on a year basis}$$

Time constant of the building:

It describes the internal thermal inertia:

$$\tau = C / (L_T + L_V) = \dots \text{ h}$$

Effective heat storage capacity:

$C = 15 * V_B = \dots \text{ Wh/K}$ for light constructions

$C = 30 * V_B = \dots \text{ Wh/K}$ for light-heavy constructions

$C = 60 * V_B = \dots \text{ Wh/K}$ for heavy constructions

Transmission factor related to volume:

$P_{T,V} = L_T / V_B = \dots \text{ W/(m}^3 \cdot \text{K)}$

LEK-factor:

This factor characterizes the heat protection of a building envelope taking into consideration the geometry of the building. It is defined as:

$LEK = 300 * U_m / (2 + I_c)$

Heating capacity related to area:

$P_1 = P_{tot} / BGF_B = \dots \text{ W/m}^2$

The total heating capacity of the building is an equation of transmission heat losses and ventilation heat losses considering the standard outside temperature:

$P_{tot} = (L_T + L_V) * (\theta_i - \theta_{ne}) = \dots \text{ W}$

Thermal energy demand related to area:

The annual heating energy demand related to the heated gross adrea of floors follows the equation:

$HWB_{BDF} = Q_h / BGF_B = \dots \text{ kWh/(m}^2 \cdot \text{a)}$

F - Further information

The EEIG EU Standards Certification Committee - The EEIG EU Standards Certification Scheme is overseen by the EEIG EU Standards Certification Committee, whose members are senior ECOLOGICAL CONSTRUCTION Organisation professionals. The members bring a broad spread of knowledge and expertise relating to ECOLOGICAL CONSTRUCTION Organisations of all types throughout Europe. EEIG EU Standards Certification Panels, which are sub-groups of the committee, meet regularly to consider applications and returns. These decisions are reviewed at annual EEIG EU Standards Certification Committee meetings.

The assessing organisations - The organisations that assess ECOLOGICAL CONSTRUCTION Organisations for EEIG EU Standards Certification are Certified EEIG Quality Systems Assessors and Validators at the various EEIG National Offices. Certified EEIG Quality Systems Assessors and Validators can be registered after relevant training by EUROCOTT – IEM, the education & training commission of the EEIG. These assessors/validators assess each ECOLOGICAL CONSTRUCTION Organisation's application or return. The assessments are passed to the EEIG EU Standards Certification Secretariat at PO Box 40668, Larnaca 6306, Cyprus where they are processed, quality assured and scheduled to be presented to an EEIG EU Standards Certification Panel for final issue of Certification.

Keeping EEIG Certified status - Once a ECOLOGICAL CONSTRUCTION Organisation has been awarded EEIG Certified status, it must prove that it continues to meet the requirements of the scheme by sending an EEIG EU Standards Certification return to the assessing organisation every two to three years, as required.

Changes to the EEIG EU Standards Certification standard - Over time, the requirements for the EEIG EU Standards Certification standard may change to make sure they remain up to date with developments in the sector and in line with current practice. When changes are made, all EEIG

Certified ecological construction Organisations will be given reasonable notice of the changes before they are expected to meet the revised requirements.

Changes to EEIG Certified status - If an ecological construction Organisation stops meeting the EEIG EU Standards Certification requirements, the ecological construction organisation's status may be reduced to 'provisional' or it may lose its EEIG EU Standards Certification status altogether. This decision would be taken by an EEIG EU Standards Certification Panel after discussing the matter with the ecological construction organisation and the relevant assessing organisation.

If an ecological construction organisation fails to provide their EEIG EU Standards Certification returns within the timescale allowed it may lose its EEIG EU Standards Certification status.

An ecological construction organisation can ask to be removed from the EEIG EU Standards Certification scheme.

G - APPENDIX 1 – Staff Competency Training

Core Skill Sets

1. **Communication** - ecological construction organisation staffs show that they can communicate effectively when they:
 - read, retain, and apply published ideas
 - write clearly and accurately in a variety of contexts and formats
 - speak clearly and coherently in both formal and informal settings
 - demonstrate active listening skills and effective interpersonal communication
 - employ the vocabulary of the subject being studied
 - become proficient in a second language or in an alternative form of communication
2. **Information Competency** - ecological construction organisation staffs show that they have information competency skills when they:
 - recognize the need for information and/or identify and clarify the question that needs to be answered
 - differentiate between major and minor arguments or ideas
 - find and interpret relevant information from text, tables, graphs, maps, media, personal communication, observation, and electronic databases
 - evaluate authority, veracity and bias of information
 - utilize the data gathered to draw conclusions or to create new sources of information that can be shared with others
 - document their sources of information
 - use technology to acquire and process information
3. **Critical Thinking and Problem Solving** - ecological construction organisation staffs show that they have critical thinking and problem solving skills when they:
 - evaluate their own beliefs, biases, and assumptions
 - evaluate strengths, weakness, and fallacies of logic in arguments and information
 - apply lessons from the past or learned knowledge and skills to new and varied situations
 - apply the principles of scientific reasoning to solve problems
 - perform basic computations or approach practical problems by choosing appropriately from a variety of mathematical techniques
 - devise and defend a logical hypothesis to explain observed phenomenon
 - recognize a problem and devise and implement a plan of action
4. **Creative Expression** - ecological construction organisation staffs demonstrate creative expression when they:
 - generate new ideas, express themselves creatively, or solve complex problems in an original way
 - collaborate to perform the work of others or to create original work
 - apply feedback to improve their performance

- evaluate diverse artistic works in varied media
5. **Civic Responsibility** - ecological construction organisation staffs show an ability to assume civic responsibility when they:
- demonstrate a knowledge of current events and social issues
 - work effectively as a leader and/or participant in group settings
 - assume civic, political, or social responsibilities
 - identify their personal convictions and explore options for putting these convictions into practice
 - accept responsibility for their own actions
 - demonstrate respect for a diversity of ideas and the rights of others
 - exhibit personal, professional, and academic honesty
 - display behavior consistent with the ethical standards within a discipline or profession
6. **Social Interaction and Life Skills** - ecological construction organisation staffs show that they have effective social interaction and life skills when they:
- work as an effective member of a team
 - demonstrate etiquette both in face-to-face and written interactions and communications
 - use language as appropriate to the situation
 - utilize conflict resolution skills when appropriate
 - demonstrate the ability to give and receive constructive feedback
 - apply time management skills to complete a task
 - develop stress management skills and/or other skills to maintain health and wellness

H - Competency Skill Sets Available through EUROCOTT

THHCOR01A	Work with Colleagues & Customers
THHCOR02A	Work in a Socially Diverse Environment
THHCOR03A	Follow Health, Safety and Security Procedures
THHGHS01A	Follow Workplace Hygiene Procedures
THHGLE02B	Implement workplace health, safety and security procedures
THHGCS03B	Deal with conflict situations
THHGTR01B	Coach others in job skills
THHCO01A	Develop and Update Hospitality Industry Knowledge

I - GLOSSARY OF ECOLOGICAL TERMS & SYSTEM OF NOTATION

Heated zone: rooms which are, with regard to their usual destination, heated directly or in-directly together with other rooms

Unheated zone: rooms which are not a part of a heated zone, especially attics, cold cellars, added car-parks, and winter gardens

Winter garden: Glas porch which is ventilated but not permanently opened to adjacent heated room

Outside temperature: Temperature of the open air

Indoor temperature: also “target temperature”; temperature of the heated zone which is the basis of calculation

Heat loss: quantity of thermal energy which passes from the heated zone to the outside surroundings by heat transport or ventilation (dissipation heat)

Heat gain: quantity of thermal energy which arises within the heated zone or enters into it independently of the heating system

Heat gain factor: Percentage of solar energy profit which gets into a building and other thermal energy which arises in the building and can be used for heating purposes

Effective heat storage capacity: Amount of the storage capacity of thermal energy which influences the need of heating energy

Heat demand: Calculated amount of thermal energy to maintain a fixed indoor temperature

Heating energy demand: Calculated demand of primary energy which is needed to cover the thermal energy with regard to transformation losses

Heating period: Period during which a building is heated

Heating threshold temperature: Outside temperature which is sufficient to hold a fixed indoor temperature in a building without heating

J - System of notation

Symbol	Denomination	Unit
a	numeric parameter for the extent of exploitation	-
A_B	area of the building which emits thermal energy	m^2
A_f	area of a frame and door	m^2
A_g	area of glass	m^2
A_i	area of part of the building	m^2
A_w	area of window	m^2
BGF_B	gross area of heated floor	m^2
$BGF_{B,DG}$	gross area of heated attic	m^2
C	effective heat storage capacity	Wh/K
c_a	specific thermal capacity of the air	Wh/(kg.K)
d	thickness of a construction part	m
f_g	percentage of glass of transparent construction parts	-
f_i	temperature correction factor of the construction part i	-
f_s	reduction factor for shading	-
g	total energy permeability of glass	-
g_w	effective energy permeability extent of glass	-
h_{DG}	gross height of the attic storey	m
HGT	heating grade days per month	Kd/M
	heating grade days per heating period	Kd/a
HT	number of heating days per months	d/M
	number of heating days per heating period	d/a
HWB_{BGF}	thermal energy demand related to area	kWh/(m^2 .a)
I_j	radiation intensity with orientation j per month	kWh/(m^2 .M)
	radiation intensity with orientation j per heating period	kWh/(m^2 .a)
l_c	characteristic length of the building	m

k	thermal transmission factor	kWh/(m ² .h.°C)
L _e	transmission factor for construction parts which border on the fresh air	W/K
LEK	special LEK factor	-
l _g	length of the glass frame	m
L _g	transmission factor for construction parts which touch the ground	W/K
L _T	transmission factor of the building envelope	W/K
L _u	transmission factor for construction parts which border on unheated rooms	W/K
L _v	ventilation factor of the building envelope	W/K
L _χ	additive factor for point-based thermal bridges	W/K
L _ψ	additive factor for linear thermal bridges	W/K
n	air-exchange rate	1/h
n _x	additional air-exchange rate by wind and buoyancy	1/h
P ₁	heating capacity related to area	W/m ²
P _{T,V}	transmission factor related to volume	W/(m ³ .K)
P _{tot}	heating capacity of the total building	W
Q _h	quantity of heating energy demand per month	kWh/M
	quantity of heating energy demand per heating period	kWh/a
q _i	middle heat flow density of internal heat gains	W/m ²
Q _i	internal heat gains per month	kWh/M
	internal heat gains per year	kWh/a
Q _s	solar heat gains via transparent construction parts per month	kWh/M
	solar heat gains via transparent construction parts per year	kWh/a
Q _T	transmission heat loss per month	kWh/M
	transmission heat loss per year	kWh/a
Q _v	ventilation heat loss per month	kWh/M
	ventilation heat loss per year	kWh/a
q _{v,f}	air-flow volume by mechanical ventilation	m ³ /h
R _{si}	heat transfer resistance of inside air to construction surface	m ² .K/W
R _{se}	heat transfer resistance of construction surface to outside air	m ² .K/W
SPF	seasonal performance factor (ratio heating output to electric power input)	-
U _f	heat transfer coefficient of frames	W/(m ² .K)
U _g	heat transfer coefficient of glass	W/(m ² .K)
U _i	heat transfer coefficient of construction part i	W/(m ² .K)
U _m	middle heat transfer coefficient of heat emitting building envelope	W/(m ² .K)
U _w	heat transfer coefficient of windows	W/(m ² .K)

V_B	heated gross volume of the building	m^3
$V_{B,DG}$	heated gross volume of developed attic	m^3
V_N	ventilated net volume of the building	m^3
WE	thermal energy unit	kWh/m^2
γ	ratio of heat gains to heat losses	-
η	exploitation factor of heat gains	-
η_v	efficiency of the heat recovery system	-
$\eta_{v,eff}$	effective heat supply factor of the heat recovery system	-
λ	measurement of the heat conductivity	$W/(m.K)$
θ_i	middle inside temperature during one month or heating period	$^{\circ}C$
θ_e	middle outside temperature during one month or heating period	$^{\circ}C$
θ_{ne}	standard outside temperature	$^{\circ}C$
ρ_a	density of the air	kg/m^3
τ	time constant of the building	h
ψ_g	correction coefficient for heat bridges between frame and glass	$W/(m.K)$

Index figures:

a	air	c	characteristic	e	external
f	fan, frame	g	ground, glass	h	heating, heated
i	internal, numerator	j	orientation	m	middle
s	solar	se	external surface	si	internal surface
u	unheated	v	ventilated	w	window, effect.
x	extra	B	gross, heated	N	net
s	shading	T	transmission	v	ventilation, vol.

K - List of relevant factors and coefficients

Chart 1: Heat transfer resistances and temperature correction factors

	Heat transfer resistance in $m^2.K/W$			temperature cor- rection factor	
	R_{si}	R_{se}	$R_{si} + R_{se}$	f_i	
Construction parts bordering to the outside air:					
outside wall, not ventilated	0.13	0.04	0.17	1.0	
outside wall, ventilated	0.13	0.13	0.26	1.0	
outside ceiling, upwards, not ventilated	0.10	0.04	0.14	1.0	
outside ceiling, upwards, ventilated	0.10	0.10	0.20	1.0	
outside ceiling, downwards, not ventilated	0.17	0.04	0.21	1.0	
outside ceiling, downwards, ventilated	0.17	0.17	0.34	1.0	
roof batter, not ventilated	0.10	0.04	0.14	1.0	
roof batter, ventilated		0.10	0.10	0.20	1.0

Construction parts bordering to unheated rooms:

wall to unheated attic	0.13	0.13	0.26		0.9
ceiling to unheated attic	0.10	0.10	0.20		0.9
wall to underground car park	0.13	0.13	0.26		0.9
ceiling to underground car park	0.17	0.17	0.34		0.9
wall to unheated winter garden	0.13	0.13	0.26		
single glazing $U > 2.5 \text{ W}/(\text{m}^2.\text{K})$				0.7	
insulation glass $U < 2.5 \text{ W}/(\text{m}^2.\text{K})$				0.6	
heat-protection glass $U < 1.6 \text{ W}/(\text{m}^2.\text{K})$					0.5
wall to unheated basement	0.13	0.13	0.26		0.5
ceiling to unheated basement		0.17	0.17	0.34	0.5
wall to unheated stairwell which is					
exposed to outside air	0.13	0.13	0.26		0.5
wall to inner courtyard with glass roof	0.13	0.13	0.26		0.5
wall to other buffer room	0.13	0.13	0.26		0.5
ceiling to other buffer room, upwards	0.10	0.10	0.20		0.5
ceiling to other buffer room, downwards	0.17	0.17	0.34		0.5
<u>Construction parts touching the soil:</u>					
wall touching the soil	0.13	0.00	0.13		0.6
floor touching the soil	0.17	0.00	0.17		0.5

Chart 2: Temperature correction factor to tempered adjoining rooms and buildings

Construction parts bordering to slightly tempered buildings or parts of buildings e.g. car parks, workshops, halls, storehouses, shelters

wall to neighbouring building part, slightly retained	$f_i = 0.8$
wall to neighbouring building part, well retained	$f_i = 0.7$
wall to neighbouring stables (only sensible heat of animals)		
if stable construction is not retained	$f_i = 0.5$
wall to neighbouring stables (only sensible heat of animals)		
if stable construction is well retained	$f_i = 0.4$

Chart 3: Heat transfer coefficients of glass and total energy permeability of glass

	U_g in $\text{W}/(\text{m}^2.\text{K})$	g
Single glazing 6 mm	5.8	0.83
Double insulation glass 6-8-6	3.2	0.71
Double compound glass 6-30-6	2.7	0.72
Triple insulation glass 6-12-6-12-6	1.9	0.63
Double heat-protection glass coated 4-16-4 (air)	1.5	0.61
Double heat-protection glass IR coated 4-14-4 (Ar)	1.35	0.62
Double heat-protection glass low coated 4-16-3 (Ar)	1.25	0.58
Double heat-protection glass IR coated 4-14-4 (Kr)	1.2	0.62
Double heat-protection glass low coated 4-10-4 (Kr)	1.1	0.58
Double heat-protection glass low coated 4-8-4 (Kr)	1.0	0.58
Triple heat-protection glass 2xIR coated 4-8-4-8-4 (Kr)	0.75	0.48
Triple heat-protection glass 2xIR coated 4-16-4-16-4 (Ar)	0.65	0.48

Triple heat-protection glass 2xIR coated 4-16-4-16-4 (Kr)	0.55	0.48
Triple heat-protection glass 2xIR coated 4-8-4-8-4 (Xe)	0.55	0.42
Double sun-protection glass 6-15-6 (Ar)	1.3	0.25
Double sun-protection glass 6-12-4 (Ar)	1.4	0.27
Double sun-protection glass 6-15-4 (Ar)	1.4	0.33
Acrylic glass for light cupola windows, double-leaf	2.7	0.70
Acrylic glass for light cupola windows, triple wall	2.0	0.60

Chart 4: Heat transfer coefficients U_f of wooden frames

thickness d_f in mm	soft-textured wood (500 kgs/m ³) $\lambda = 0.13$ W/(m.K)	hardwood (700 kgs/m ³) $\lambda = 0.18$ W/(m.K)
30	2.3	2.70
50	1.8	2.35
70	1.6	2.05
90	1.5	1.85
110	1.3	1.65

Chart 5: Heat transfer coefficients U_f of wood-aluminium frames

thickness d_f in mm	U_f in W/(m ² .K)
30	2.35
50	1.8
70	1.6
90	1.5
110	1.3

Chart 6: Heat transfer coefficients U_f of plastic frames

Polyurethane	2.6
PVC hollow profile 2 cavities	2.2
3 cavities	2.0
3 cavities + alu skin	2.0
4 cavities	1.5
4 cavities + alu skin	1.5
5 cavities	1.3
5 cavities + alu skin	1.3

Chart 7: Heat transfer coefficients U_f of high heat-insulating frames

alu frames	0.9
wood-alu frames	0.9
wood frames + fossile or foamed insulating material	0.9
wood frames + natural insulating material	1.0
plastic frames	0.9

Chart 8: Heat transfer coefficients U_f of metal frames

with thermal separation	4.0
without thermal separation	6.0

Chart 9: Heat transfer coefficients U_f of light-cupola frames

frames with 30 cm PP apron	2.0
frames with 50 cm PP apron	1.8

Chart 10: Correction coefficient for heat bridges between frame and glass

	double and multiple glass, uncoated correction coefficient ψ_g	double and triple insulating glass, with coating
wood and plastic frames	0.04	0.06
metal frames with thermal bridge stoppage	0.06	0.08
metal frames without thermal bridge stoppage	0.00	0.02

Chart 11: Measurement of the heat conductivity and thickness of insulating materials

	λ (W/mK)	d (kg/m ³)
<u>construction panels:</u>		
gypsum boards or gypsum fibre	0.21	900
wood fibre soft (d = 18, 22, 24 mm)	0.055	270
soft (d = 36 mm)	0.050	250
soft (d = 40, 60, 80, 100 mm)	0.40	160
semi-hard	0.10	600
hard	0.15	1000
extruded particle boards, standard	0.13	700
cement-bound	0.26	1250
OSB	0.13	600
plywood panels	0.15	600
fibre-cement boards	0.60	2000
aerated structure boards	0.12	500
wood-wool boards	0.10	400
earth building panel	0.14	500
reed or straw panels, unplastered	0.056	190
high insulating panels, EPS, cement-bound	0.07	140
<u>insulating materials:</u>		
mineral wool	0.04	15-50
mineral fibre panels 50 – 80 kg/m ³	0.037	50-80
> 80 kg/m ³	0.039	80-170
sheep's wool	0.04	10-30
cotton	0.04	25-30
flax	0.04	20
coconut mats	0.045	60-90
cork, fine, expanded	0.042	120-200
multicellular glass, light	0.045	120
heavy	0.050	160

cellulose flocks and panels B2	0.039	30-70
cellulose flocks B1	0.045	30-70
EPS polystyrole, expanded	0.04	15-18
XPS-G polystyrole, extruded	0.035	35
XPS-R polystyrole, extruded	0.037	35
PU polyurethane	0.03	30-80

masonry bricks and concrete:

bloating bricks, solid	0.18	800
cavity	0.22	650
hollow concrete blocks	0.6	1500
wood-chip concrete	0.45	1500
clinker bricks	1.8	1800
solid bricks	0.7	1600
cavity bricks	0.38	1200
partition wall bricks	0.38	1100
porous cavity bricks	0.25	800
high porous cavity bricks with insulating mortar	0.18	650
sound-absorbing bricks	0.55	1700
natural stone masonry	2.3	2600
aerated concrete blocks, 400 kgs	0.11	400
500 kgs	0.14	500
600 kgs	0.16	600
800 kgs	0.24	800
solid clay (earth)	1.0	2000
light loam, 800-1200 kgs	0.3	1200
600-800 kgs	0.16	800
armoured concrete	2.3	2400
cast and compacted concrete	1.6	1800
lightweight concrete	0.5	1100
ceilings: cavity bricks with concrete topping	0.8	1400
hollow concrete with concrete topping	0.8	1400
porous filler bricks	0.67	1000
hollow core slab, solid concrete	1.33	1800
hollow core slab, light concrete	1.0	1400

mortar and plastering coars:

cement mortar	1.4	2200
cement-lime mortar	1.0	1800
insulating mortar EPS (polystyrole) or perlite	0.28	800
PIR polyisocyanurate	0.033	35-80

wood, dry-to-fit (8 -15%relative humidity):

conifer wood, heat flow at right angles to fibre	0.13	500
heat flow lengthways to fibre	0.22	500
deciduous wood	0.16	800

floorings and floor coverings:

cement screed	1.4	2000
anhydrite flowing screed, standard	1.1	2000
porous	0.4	1200
asphaltic screed	0.8	2200
ceramic coverings	1.2	2000
adhesive hard-wood parquet floor	0.22	850
cork panels	0.06	300
linoleum floor	0.18	1000
cork-linoleum floor	0.08	700

pure materials:

steel	60	7800
copper	380	8900
aluminium	200	2800
glass	0.8	2500
acrylic glass	0.19	1180
PE-sealing mats, bitumen flaming-roofing felt	0.26	1700
Ni Cr-steel, stainless	13	7700

fillings:

perlite	0.05	100
expanded mica	0.07	100
expanded clay	0.11	350
grinded cork, expanded	0.042	90
natural	0.06	140
cellulose, loose	0.042	35
polystyrole, loose	0.044	10
mineral wool, loose	0.044	15
sawdust, wood chippings	0.1	200
slag, cinders	0.35	750
EPS, granulate, cement-bound	0.7	250
bitumen-bound	0.05	125
perlite, expanded, hydrophobized	0.042	100
sand, gravel, air-dry	0.7	1800
20% humidity	1.4	1650
